



Communication
 1 to actuator
 1 to slave
 1 from master or t'stat
 (RJ45 plugs interchangeable)

Power
 (RJ12 Plugs
 are interchangeable)

Changeover Sensor Notes:

- Thermistor to be installed in ductwork
- Disconnect sensor from all drones

————— Communication Cable (RJ45/RJ45)
 - - - - - Power Cable (RJ12/RJ12)

FILE: VSD1WIR1US	Wiring Schematic Single Master with Optional Drones	DATE	2/07	
SCALE		N.T.S.	DRW No.	RADUS10
CHECKED BY			REV	N/A



www.rickardus.com